

LAKE SHERWOOD - WATER FECAL COLIFORMS COMPOSITE TEST RESULTS 2009-2013

(fecal coliforms/100ml)

Sample #	2009			2010			2011		2012		2013	
	05/09	09/09	10/09	04/10	08/10	09/10	05/11	09/11	06/12	09/12	06/13	
#1 Clubhouse Bridge	40	1700	3000	800	400	200	400	700	<20	20	<20	
#2 Aerator #1 Lot 55	40	6000	700	1300	4700	200	400	400	<20	20	220	
#3 Aerator #3 Center 1hp	110	1300	3000	200	1700	400	2200	0	<20	<20	20	
#4 Aerator #5 Lot 28	500	2100	1100	400	130000	1700	400	200	20	<20	110	
#5 Aerator #2 Lot 67	200	900	800	400	400	400	200	200	<20	<20	40	
#6 Retirement Village	70	5000	700	<20	22000	400	800	1100	20	40	340	
#7 Holly Ridge				1300	2400000	800	<20	3000	300	300	80	

FECAL COLIFORMS STANDARDS:

Primary (swimming, skiing, diving) Contact Recreation = 400/100ml

Secondary (fishing, wading, boating) Contact Recreation = 2000/100ml